

# Aberdeen Fire Rescue Department



*Serving the community since 1921*

910-944-7888

800 HOLLY STREET  
ABERDEEN, NC 28315

Fax: 910-944-9755



## Fire Alarm Systems

Building: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_

Date of Last Inspection: \_\_\_\_\_ Outstanding Violations: Yes  No

### General

Were building alterations/renovations made since last inspection? Yes  No

Has a new alarm been added since last inspection? Yes  No

Were new detectors or alarms added since last inspection? Yes  No

### Control Panel

Is green power light on? Yes  No

Are any trouble lights on? Yes  No

If yes, why? \_\_\_\_\_

Are supervisory lights on? Yes  No

If yes, why? \_\_\_\_\_

Does panel appear in good condition? Yes  No

### Batteries

Are batteries in good condition without signs of corrosion? Yes  No

### Fire Alarm Boxes (Manual Stations)

Are fire alarm boxes clear, unobstructed, and identified? Yes  No  N/A

### Fire Alarm Notification Appliances

Do number and location of fire alarm notification appliances appear adequate? Yes  No  N/A

### Quarterly Tests Recorded

Test of fuses? Yes  No  N/A

Test of interfaced equipment? Yes  No  N/A

Test of panel lamps or LED's? Yes  No  N/A

Test of supervisory signal devices (except tamper switches)? Yes  No  N/A

Test of off-premises transmission equipment? Yes  No  N/A

### Semiannual Tests Recorded

Lead acid battery discharge test? Yes  No  N/A

Lead acid battery load test? Yes  No  N/A

Lead acid battery specific gravity test? Yes  No  N/A

